隘

CERTIFICATE

No. B 17 10 87944 008



Production Facility(ies):

02459

Certification Mark:



Product: Connector

Connectors for Photovoltaic Systems

Model(s): PV-LHT3M, PV-LHT3F, PV-LHT4M, PV-LHT4F,

PV-CXLH0601-1, PV-LH0601-2, PV-LH0601-3.

Parameters: Rated Voltage: 1500VDC

Rated Current: 30A
Application Class: A
Protection Class: II

Degree of Protection: For IP67 use Ambient Temperature: -40°C~ + 85°C

Tested according to: IEC 62852(ed.1)

EN 62852:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704071715403-00

Valid until: 2022-10-09

Date, 2017-10-10 (Yaqun Liu)

Page 1 of 1

