

## Accessories ZB 4/6

### Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16 D-32758 Detmold

Germany

Fon: +49 5231 14-0 Fax: +49 5231 14-292083 www.weidmueller.com







### **Building installation wiring**

For building installations, we offer a complete system that revolves around the 10×3 copper rail and comprises perfectly coordinated components: from installation terminal blocks, neutral conductor terminal blocks and distribution terminal blocks to comprehensive accessories such as busbars and busbar holders.

### General ordering data

Туре	ZB 4/6
Order No.	<u>0556700000</u>
Version	Accessories, Clamping yoke for busbar, Rated cross-section: Clamping yoke, Feed-through (bushing)
GTIN (EAN)	4008190188412
Qty.	50 pc(s).



### **Accessories ZB 4/6**

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16 D-32758 Detmold Germany

Fon: +49 5231 14-0 Fax: +49 5231 14-292083 www.weidmueller.com

### **Technical data**

### **Dimensions and weights**

Width	5.3 mm	Width (inches)	0.209 inch
Height	12 mm	Height (inches)	0.472 inch
Depth	20 mm	Depth (inches)	0.787 inch
Net weight	2.88 g	-	

### **Material data**

Safety notice

Material	Steel	Colour	Silver

### **Rating data IECEx/ATEX**

Certificate No. (ATEX)	DEMKO03ATEX136028U	Certificate No. (IECEX)	IECEXULD13.0005U
Wire cross section max. (ATEX)	4 mm <sup>2</sup>	Wire cross section max. (IECEX)	4 mm <sup>2</sup>
Operating temperature range	For operating temperature range see EC Design Test Certificate / IEC Ex-	Ex 2014/34/EU label	
	Certificate of Conformity		II 2 G D

Installation instructions: The potential equalisation (PE) rail modules are suitable for use in housings in atmospheres with flammable gases and dust. For use in areas with flammable gases, these housings must meet the requirements of EN 60079-0 and EN 60079-7. For use in areas with flammable dust, these housings must meet the requirements of EN 60079-0 and EN 60079-31. When combined with

other terminal block ranges and sizes, and when other accessories are used, you must comply with the clearance and creepage distances given. Regarding accessory use, the manufacturer's instructions must be followed. List of restrictions: The PE rail modules component, with Ex marking when used with the busbar holders of type SH and WEW. When used independently, the

# are considered one

above named components are not covered by this certificate.

### System specifications

Version for busbar 6 x 6 mm



## Accessories ZB 4/6

### Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16 D-32758 Detmold

Germany

Fon: +49 5231 14-0 Fax: +49 5231 14-292083 www.weidmueller.com

### **Technical data**

### **Additional technical data**

Installation advice	Feed-through (bushing)	Type of mounting	Screwed
CSA rating data			
Certificate No. (CSA)	12400-237	Wire cross section max. (CSA)	10 AWG
Wire cross section min. (CSA)	26 AWG		-

### **Conductors for clamping (rated connection)**

Clamping screw	M 3	Stripping length	16 mm
Tightening torque, min.	1.2 Nm	Type of connection	Clamping yoke
Wire connection cross section, finely		Wire connection cross section, sol	id
stranded, max.	4 mm²	core max. rated connection	6 mm²
Wire connection cross section, so	olid	Wire connection cross-section, fine	ely
core, min. rated connection	0.5 mm <sup>2</sup>	stranded, min.	0.5 mm <sup>2</sup>

### Classifications

ETIM 3.0	EC00001	ETIM 4.0	EC000001
ETIM 5.0	EC00001	ETIM 6.0	EC002848
UNSPSC	30-21-18-11	eClass 5.1	27-14-11-31
eClass 6.2	27-14-11-90	eClass 7.1	27-14-11-90
eClass 8.1	27-14-11-90	eClass 9.0	27-14-11-90
eClass 9.1	27-14-11-92		

### **Approvals**

Approvals



ROHS Conform

### **Downloads**

Engineering Data	EPLAN, WSCAD
Engineering Data	0556700000_06744_ZB_4-6_STP.stp STEP